


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY**  
**CONDITION**  
**CERTIFICATE**

No. 1456Date: 04/10/2019

It is certified that an inspection team headed by Padma Gome  
Assistant Engineer (Name of  
 Officers with designation) from Public Health Engineering Department Sub Div. Indore  
 (Name of Department/Office) inspected the  
Sardar Patel International School &  
Village Begam Khedi, Post Burana Khedi, Indore (M.P.) (Name & Address  
 of the School) on 04/10/2019 and found that the Sardar Patel  
International School, Indore (Name of school) has  
 safe drinking water facilities for the students and members of staff of the institution  
 and is maintaining the hygienic sanitation condition in the school building & the  
 campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 5-year.

Signature with Seal:   
Assistant Engineer  
 Name P. B. L. Sub-Div. INDORE

Designation : \_\_\_\_\_

To

SARDAR PATEL INTERNATIONAL SCHOOL  
VILLAGE BEGAM KHEDI  
POST BURANA KHEDI, INDORE (M.P.)

(Name &amp; Address of the Institution)

**Office of the Assistant Engineer**  
**P H E Sub Division, Indore (M. P.)**

Analysis report	
Type of Sample <u>Water Sample</u>	
Particulars of Sender <u>Sample Submitted by Mr. Balram Patidar</u>	
Particulars of Sample Collected/Not Collected by P.H.E.D.	
Sample No.	Sample Details
<u>11</u>	<u>SARDAR PATEL INTERNATIONAL SCHOOL, Khatoukherdi, Begumkhedi Indore</u>
Date of Collection	
Particulars to be filled in the laboratory	
Date of Receipt <u>3/10/2019</u>	Time of receipt
Lab. Reference No. <u>A.E. Inward No. 1324 Date 28/9/19</u>	Tested on

Physical, Chemical and Bacteriological Analysis

S. No.	Tests	Unit	As per BIS-10500:2012 For drinking water		Results				
			Requirements (Desirable) Limit	Permissible Limit in the absence of alternative source	Sample No.	Sample No.	Sample No.	Sample No.	
					<u>11</u>				
1	Temperature	°C	—	—	—				
2	Colour	Hazen units	5	15	—				
3	Odour		Agreeable	Agreeable	—				
4	Turbidity	N.T.U.	1	5	<u>1.5</u>				
5	Total Dissolved Solids	mg/l	500	2000	—				
6	pH	pH Scale	6.5 – 8.5	No Relaxation	<u>7.6</u>				
7	Iron	mg/l	0.3	1	—				
8	Nitrate	mg/l	45	45	<u>12</u>				
9	Arsenic	mg/l	0.01	0.01	<u>0.01</u>				
10	Fluoride	mg/l	1	1.5	<u>0.61</u>				
11	Chloride	mg/l	250	1000	<u>104</u>				
12	Total Alkalinity	mg/l	200	600	<u>351</u>				
13	Calcium Ion	mg/l	75	200	<u>61</u>				
14	Magnesium Ion	mg/l	30	100	<u>42</u>				
15	Residual Chlorine	mg/l	0.2	1	<u>0</u>				
16	Sulphate	mg/l	200	400	<u>40</u>				
17	Manganese	mg/l	0.1	0.3	—				
18	Total Hardness	mg/l	200	600	<u>382</u>				
19	Total Coliform	Colony/100 ml	0	0	<u>0</u>				
20	Fecal Coliform	Colony/100 ml	0	0	<u>0</u>				

Remark: This water sample is safe for drinking purpose.

*Ganesh*  
Signature

*Pge 2*  
Page