

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION
CERTIFICATE**

No. 1456

Date: 04/10/2019

It is certified that an inspection team headed by Padma Gome
Assistant Engineer (Name of

Officers with designation) from Public Health Engineering Department Sub Div Indore

(Name of Department/Office) inspected the

Sardar Patel International School, 21-22 Shakti Vihar colony
Bangali Square Khadwa Road Indore (Name & Address

of the School) on _____ and found that the _____

SARDAR PATEL INTERNATIONAL SCHOOL (Name of school) has
safe drinking water facilities for the students and members of staff of the institution
and is maintaining the hygienic sanitation condition in the school building & the
campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of _____.

Signature with Seal: Assistant Engineer

Name P. M. E. Sub-Div. INDORE

Designation : _____

To
SARDAR PATEL INTERNATIONAL
SCHOOL & VILLAGE KHATRI
KHEDI, BEGAM KHEDI KANADIA ROAD
(Name & Address of the Institution) INDORE (M.P.)

Office of the Assistant Engineer
P H E Sub Division, Indore (M. P.)

Analysis report	
Type of Sample	Water Sample
Particulars of Sender	Sample Submitted by Mr. Balram Patidar
Particulars of Sample	Collected/Not Collected by P.H.E.D.
Sample No.	Sample Details
11	SARDAR PATEL INTERNATIONAL SCHOOL, Khaloukherdi, Begun Khedi Indore
Particulars to be filled in the laboratory	
Date of Receipt	3/10/2019
Lab. Reference No.	A.E. Inward No. 1324 Date 28/9/19
	Tested on

Physical, Chemical and Bacteriological Analysis

S. No.	Tests	Unit	As per BIS-10500:2012 For drinking water		Results			
			Requirements (Desirable) Limit	Permissible Limit in the absence of alternative source	Sample No.	Sample No.	Sample No.	Sample No.
1	Temperature	°C	—	—	11			
2	Colour	Hazen units	5	15	—			
3	Odour		Agreeable	Agreeable	—			
4	Turbidity	N.T.U.	1	5	1.5			
5	Total Dissolved Solids	mg/l	500	2000	—			
6	pH	pH Scale	6.5 – 8.5	No Relaxation	7.6			
7	Iron	mg/l	0.3	1	—			
8	Nitrate	mg/l	45	45	12			
9	Arsenic	mg/l	0.01	0.01	0.01			
10	Fluoride	mg/l	1	1.5	0.61			
11	Chloride	mg/l	250	1000	104			
12	Total Alkalinity	mg/l	200	600	351			
13	Calcium Ion	mg/l	75	200	61			
14	Magnesium Ion	mg/l	30	100	42			
15	Residual Chlorine	mg/l	0.2	1	0			
16	Sulphate	mg/l	200	400	40			
17	Manganese	mg/l	0.1	0.3	—			
18	Total Hardness	mg/l	200	600	382			
19	Total Coliform	Colony/100 ml	0	0	0			
20	Fecal Coliform	Colony/100 ml	0	0	0			

Remark: This water sample is safe for drinking purpose.

Ganesh
Signature

Page 2