

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 386

Dated: 22/09/26

It is certified that an inspection team headed by Manish Thakkar

as an Incharge (Name of Officers with designation)
from Maintenance Sub Div No. 8 I.M.E. PHED

inspected the SARDAR PATEL INTERNATIONAL SCHOOL BEGAM KHEDI KHATRI
KHEDI KANADIYA ROAD INDORE on 18/09/26 (date of
inspection) and on the basis of Water Test Report (Attached) bearing no. DWP/26/4663

dated 18/09/26 of WTL I.M.E. Indore (PHED Lab) certified that
SARDAR PATEL INTERNATIONAL SCHOOL has safe drinking water facilities for the students and
members of staff of the institution. School is also maintains the hygienic sanitation condition in the
school building & the campus as per norms prescribed by Central/ State/ U.T. Govt.

This certificate is valid till one year from Date of issue of water purifier Drill.

Signature with Seal:

Name: Mr. Praveen Sharma

Designation: Assistant Engineer
P.H.E. Deptt.
Major Sub-Div. No. 8 (I.M.E.) Indore

Name & Address of the Office / Department:


To

SARDAR PATEL INTERNATIONAL SCHOOL
BEGAM KHEDI KHATRI KHEDI KANADIYA ROAD INDORE

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.


Director
Sardar Patel International School
INDORE (M.P.)


Principal
Sardar Patel International School
INDORE (M.P.)

Water Testing Laboratory
Indore Municipal Corporation Musakhedi Indore (MP) India
 Phone 0731-2712846 Email: ee2_narmada@rediffmail.com, waterlabimc@outlook.com



Test Report

Lab Reference No DW/26/4463	Report Page No. 1/1	Date	18.09.2026
Customer Name, Sardar Patel International School		Date of Receipt	17.09.2026
		Date of Commencement	17.09.2026
		Date of sample Collection if specified	17.09.2026
Location- Gram Begam Khedi (Khatari Khedi) Kannadiya Road Indore			
Source:- R.O			
Volume - 250 ml Glass Bottel in Unsealed			

S.No.	Characteristic	Method of Test ref. to	Unit	IS-10500-2012		Result
				Requirment Aceptable Limit	Permissible Limit in abesent of alternative Source	
1	Coliform Bacteria	IS-17819-2022 ISO9308-2 : 2012	MPN Per 100 ml	Should not be detect in 100ml		<1
2	Escherichia Coli	IS-17819-2022 ISO9308-2 : 2012	MPN Per 100 ml	Should not be detect in 100ml		<1

Note:-

1. The legal liability limited up to the analytical charges only.
 2. The results are related only to the sample tested.
 3. The reports shall not be reproduced except in full without approval.
 4. Sample not drawn by the Laboratory
 5. The result apply to the sample as received.
- Abbreviation "ND" Not detected, "BDL" Below Determination Limit

[Signature]
 Director

*** End of Report ***



[Signature]
 Director
 Sardar Patel International School
 INDORE (M.P.)

[Signature]

Principal
Sardar Patel International School
INDORE (M.P.)